



TO WHOM IT MAY CONCERN,

Date: 11 November 2024

Veolia Ref#: 02-LR-1024- 10711

Certified that Dunes International School, Riyadh bearing license number 01-OSL-000099 has safe drinking water for the students and members of staff of the institution, and is maintaining hygienic conditions in the school building and premises.

The tested parameters of drinking water sample with reference to report 02-LR-1024- 10711, is conforming to SASO 409 (Saudi Arabian Standards Organization) for Bottled Drinking Water (Gulf Standard, GS 1025).

For Veolia Water Technologies, Saudi Limited,



[Handwritten signature]
11/11/24

Veolia Water Technologies, Saudi Limited
Paid Up Capital: SR. 1,500,000, Investment License No. 101030104272-01
www.middle-east.veoliawatertechnologies.com

Riyadh Region (Head Office)



C.R.No.: 1010077639
C.R.No.: 1010054597
C.R.No.: 1010054964
P.O. Box 58515 Riyadh 11515
Office : (011) 4787001, (011) 4787721
Factory: (011) 2651599

Dammam/Khobar Region



C.R.No.: 2050012185
C.R.No.: 2051045446
C.R.No.: 2051050509
P.O. Box 3896, Dammam 31481
Office : (013) 8983075
Factory : (013) 8121034

Jeddah Region



C.R.No.: 4030235389
P.O. Box 11112 Jeddah 21453
Office : (012) 6606031

ISO 9001 /
ISO 14001 / OHSAS 18001
BUREAU VERITAS
Certification



Client Name:	DUNES SCHOOL	Site Name:	RIYADH
Request ID:	02-LR-1024- 10711	Requested By:	MUHSIN MOIDU VAYAT
Date Received:		Closed On:	10-NOV-24
Laboratory:	Riyadh	Chemist:	Hetaf Alshahrani

Dunes School				
Parameter Name	Result	UOM	Ref	CTRL Limit
pH	7.6	-	A003	6.5 - 8.5
Electrical Conductivity at 25 oC	211	µs/cm	A004	-
TDS	137	mg/l	A005	<1000
Turbidity	0.15	NTU	A002	5 max
M Alkalinity as CaCO ₃	22	mg/l	A007	N.S
Bicarbonate as HCO ₃ ⁻	27	mg/l	A007	N.S
Total Hardness as CaCO ₃	75	mg/l	A009	500 max
Ca Hardness as CaCO ₃	33	mg/l	A008	<312 max
Mg Hardness as CaCO ₃	42	mg/l	A008	208 max
Calcium as Ca ²⁺	13	mg/l	A038	125 max
Magnesium as Mg ²⁺	10	mg/l	A039	50 max
Sodium as Na ⁺	14	mg/l	A023	250 max
Total Iron as Fe ³⁺	0.01	mg/l	A025	0.3 max



The QHSE Management System
Is certified by Bureau Veritas

N.D = Non-Detected

TNTC = Too Numerous to Count

Note: This is a computer-generated document. No signature is required

Client Name:	DUNES SCHOOL	Site Name:	RIYADH
Request ID:	02-LR-1024- 10711	Requested By:	MUHSIN MOIDU VAYAT
Date Received:		Closed On:	10-NOV-24
Laboratory:	Riyadh	Chemist:	Hetaf Alshahrani

Dunes School				
Parameter Name	Result	UOM	Ref	CTRL Limit
Chloride as Cl-	20	mg/l	A014	250 max
Sulphate as SO42-	41	mg/l	A015	400 max
Silica as SiO2	1.2	mg/l	A016	N.S
Nitrate as NO3-	14.2	mg/l	A017	50 max
Total Count Bacteria	ND	CFU/100 ml	A034	-
Total Coliforms Bacteria	ND	CFU/100 ml	ISO 9308_1	-
Legionella Pneumophila	Negative	CFU/L	ASTM D8439 -21 and/or ISO 11731: 2017	-



The QHSE Management System
Is certified by Bureau Veritas

N.D = Non-Detected
TNTC = Too Numerous to Count

Note: This is a computer-generated document. No signature is required